

OPERATING SUMMARY

MOE  
WPCP  
MOO  
ATIS

1973

c.1  
a aa

# MOORE TWP. (CORUNNA)

WATER POLLUTION CONTROL PLANT

LABORATORY & RESEARCH LIBRARY  
MINISTRY OF THE ENVIRONMENT

LIBRARY COPY

MAR 13 1975

MINISTRY OF  
ENVIRONMENT

LAB

1  
9  
7  
3

Copyright Provisions and Restrictions on Copying:

This Ontario Ministry of the Environment work is protected by Crown copyright (unless otherwise indicated), which is held by the Queen's Printer for Ontario. It may be reproduced for non-commercial purposes if credit is given and Crown copyright is acknowledged.

It may not be reproduced, in all or in part, for any commercial purpose except under a licence from the Queen's Printer for Ontario.

For information on reproducing Government of Ontario works, please contact ServiceOntario Publications at [copyright@ontario.ca](mailto:copyright@ontario.ca)



Ontario

MINISTRY OF THE ENVIRONMENT

MINISTER  
Honourable William G. Newman

DEPUTY MINISTER  
E. Biggs

ASSISTANT DEPUTY MINISTER  
REGIONAL OPERATIONS  
J. Barr

REGIONAL OPERATIONS DIVISION

DIRECTOR, SOUTHWESTERN REGION  
D. McTavish

MANAGER, UTILITY OPERATIONS  
A. Ladbroke

MOORE TWP. - CORUNNA  
WATER POLLUTION CONTROL PLANT

operated for  
THE TOWNSHIP OF MOORE  
by the  
MINISTRY OF THE ENVIRONMENT


1973 ANNUAL OPERATING SUMMARY

prepared by  
Plant Performance Unit  
TECHNICAL SERVICES BRANCH  
T. Cross, Director

## CONTENTS

Title Page . . . . .	1
Flow Diagram . . . . .	4
Design Data . . . . .	5
Operating Cost . . . . .	6
Process Data . . . . .	8

# MOORE TOWNSHIP (CORUNNA) WATER POLLUTION CONTROL PLANT



## DESIGN DATA

PROJECT Moore Twp. (Corunna)  
WPCP

PROJECT NO. 2-0088-61

TREATMENT Extended Aeration

DESIGN FLOW 0.32 mgd

DESIGN POPULATION 4,000

BOD - Raw Sewage 150 mg/l  
- Removal 90-95%

SS - Raw Sewage 150 mg/l  
- Removal 90-95%

### PRETREATMENT

#### Comminution

Type: Worthington comminutor  
Size: One Model 15-C-4

#### Grit Removal

Type: C. P. Aer-Degritter with air lift  
Size: 3780 gal  
Retention: 17 min

### SECONDARY TREATMENT

#### Aeration Tanks

Type: Diffused air, Single pass  
Size: Two 84' x 17' x 14.25' (avg)  
(40,698 cu ft or 254,000 gal)  
Retention: 24.0 hours

#### Air Supply

Type: Sutorbilt  
Size: Two 1000 cfm

#### Diffusers

Type: C. P. Spargers  
Spacing: 22 per tank @ 20" c-c

### Secondary Sedimentation

Type: Dorr  
Size: Two 22' x 22' x 12½' swd  
(75,300 gal)  
Retention: 5.7 hours  
Loading: Surface, 330 gal/ft<sup>2</sup>/day  
Weir, 2,350 gal/ft/day

### CHLORINATION

Type: W & T, Manual  
Size: One 100 lb/day

#### Chlorine Contact Chamber

- in outfall

### OUTFALL


196' of 48" dia corrugated pipe to  
St. Clair River

### SLUDGE HANDLING

Type: Sludge holding tank (decanted)  
Size: One 17' x 17' x 15' (23,000 gal  
@ 12.8' depth)

# ANNUAL COSTS

## 1973 OPERATING COSTS



## YEARLY OPERATING COSTS



YEAR	SEWAGE TREATED in million gallons	TOTAL OPERATING COSTS	UNIT COSTS	
			\$/M.G.	¢/lb BOD
1968	39.9	\$ 16,555	415	21
1969	44.8	16,333	364	22
1970	46.3	18,530	401	27
1971	46.0	20,574	447	37
1972	65.7	21,434	319	24
1973	63.6	33,153	520	34

## OPERATING EXPENDITURES

SALARIES AND WAGES	<u>\$13,288</u>
EMPLOYEE BENEFITS	<u>641</u>
TRANSPORTATION & COMMUNICATIONS	<u>734</u>
SERVICES	<u>7,594</u>
SUPPLIES AND EQUIPMENT	<u>10,896</u>
ACQUISITION/CONSTRUCTION OF PHYSICAL ASSETS	<u>0</u>
TRANSFER PAYMENTS	<u>0</u>
OTHER TRANSACTIONS	<u>0</u>
TOTAL	<u>\$33,153</u>



# PROCESS DATA FLOWS





DESIGN CAPACITY - - - - -



## PLANT PERFORMANCE

MONTH	FLOWS			BIOCHEMICAL OXYGEN DEMAND				SUSPENDED SOLIDS				PHOSPHORUS	
	TOTAL FLOW	AVERAGE DAY	MAXIMUM DAY	INFLUENT	EFFLUENT	REDUCTION		INFLUENT	EFFLUENT	REDUCTION		INFLUENT	EFFLUENT
	million gallons	mil. gal	mgd	mg/l	mg/l	%	10 <sup>3</sup> pounds	mg/l	mg/l	%	10 <sup>3</sup> pounds	mg/l P	mg/l P
JAN	6.03	0.19	0.23	147	8	95	8.4	136	9	95	7.7	6.4	4.9
FEB	5.35	0.19	0.26	155	9	94	7.8	148	13	91	7.2		0.8
MAR	7.69	0.25	0.41	152	11	93	10.8	137	15	89	9.4	15.0	1.0
APR	5.11	0.17	0.33	161	6	96	7.9	179	9	95	8.7	7.4	0.5
MAY	5.58	0.18	0.27	158	8	95	8.4	143	9	94	7.5	6.2	3.4
JUNE	4.92	0.16	0.24	211	6	97	10.1	287	7	98	13.8	9.6	1.1
JULY	4.49	0.14	0.24	167	9	95	7.1	144	16	89	5.7	7.2	6.8
AUG	4.30	0.14	0.16	162	9	94	6.6	135	8	94	5.5	7.2	
SEPT	3.88	0.13	0.17	166	7	96	6.2	152	11	93	5.5	7.5	7.3
OCT	4.56	0.15	0.20	153	6	96	6.7	148	6	96	6.5	8.8	5.6
NOV	5.57	0.19	0.33	157	7	96	8.4	160	12	93	8.2	14.0	5.5
DEC	6.21	0.20	0.47	137	7	95	8.1	143	10	93	8.3	9.4	5.1
TOTAL	63.69	-	-	-	-	-	96.5	-	-	-	94.0	-	-
AVG.		0.17	MAXIMUM 0.47	163	8	95	8.0	165	10	93	7.8	9.1	3.2
No. of Samples	-	-	-	65	67	-	-	65	67	-	-	14	14



# BIOCHEMICAL OXYGEN DEMAND



# SUSPENDED SOLIDS



# PHOSPHORUS



## TREATMENT DATA

MONTH	GRIT	CHLORINATION		AERATION			WASTE SLUDGE			AEROBIC DIGESTER			
	QUANTITY REMOVED cubic feet	CL <sub>2</sub> USED pounds	AVG. DOSAGE mg/l	MLSS CONC mg/l	F/M day <sup>-1</sup>	AIR USED 1000 ft <sup>3</sup> lb BOD	QUANTITY 10 <sup>3</sup> gallons	SUSPENDED SOLIDS mg/l	VOL. SOLIDS %	QUANTITY REMOVED 10 <sup>3</sup> gallons	SUSPENDED SOLIDS mg/l	VOL. SOLIDS %	AMOUNT HAULED cubic yards
JAN	15	310	5.2	6270	0.03	5.4	45	11000	68	18.0			107
FEB	13	280	5.3	7370	0.03	5.2	50	11400	64	32.4	3.6	66	192
MAR	23	310	4.0	5880	0.05	4.1	210	14000	56	18.0	3.0	61	107
APR	16	290	5.7	4830	0.04	5.5	100	11900	42	0			0
MAY	18	310	5.6	4940	0.04	5.3	65	12100	54	88.2	3.1	57	523
JUNE	18	300	6.1	5190	0.05	4.4	32	8800	60	13.5			80
JULY	18	310	6.9	4150	0.04	6.5	70	6400	59	18.0	1.3	56	107
AUG	16	310	7.2	3920	0.04	6.7	75	8700	64	24.0	2.9	54	144
SEPT	18	300	7.7	3550	0.09	6.9	30	6200	66	21.0	2.6	59	125
OCT	18	310	6.7	3930	0.04	6.5	50	7300	71	25.5	1.1	67	152
NOV	18	300	5.4	4190	0.06	5.0	47	5500	70	12.0			70
DEC	16	310	5.0	5000	0.04	5.5	80	11000	39	27.0	1.2	62	160
TOTAL	207	3640	-	-	-	-	854	-	-	297.6	-	-	1767
AVG.	3.2 cu. ft/mil gal	10	5.7	4940	0.05	5.6	71.2	9520	59	27.1	2.3	60	161